承保範圍　　　It is a condition precedent to recovery hereunder, that the following Fire Protection Steps must be complied with Commencing with the first placement of manufacturing tools into the plant(s), it is agreed that:

A. The whole existing fire protection system(s) installed for the operation of the plant shall be activated. No subsequent disablement or disarming of the fire protection system, in parts or as a whole, shall be undertaken without prior written notice to the leading insurers.

B. Private water supply and private hydrants and standpipes for the plant(s) shall be activated, charged, and on adequate water supply maintained. No subsequent disablement or disarming of the hydrants, standpipes, and water supply shall be undertaken without prior written notice to the leading

C. The proprietary alarm system and station for Smoke Detection and Sprinkler Flow Alarms (if available shall be activated and tested. Two ERC staffs shall be in _____-hour attendance with the capacity to mobilize Emergency Response Team effectively at all times. A written procedure shall exist for staff to contact Fire department immediately upon receipt of alarm.

D. Formal contractor control procedures encompassing contractor fire training, contractor access to the plant, and hotwork permits procedures shall be developed and implemented by the assured.

E. Commencing only with the operational testing of tools and equipment in the plant(s), an Emergency Response Team (ERT), consisting of trained staff and or contractors shall be on premises at all times. Security staff at the control center must be able to get hold of ERT position and status at all times.

F. Portable CO_2 shall be easily accessible within ____ seconds from all equipment with potential fire hazard as identified by its safety tag.

Failure to comply with this condition may render this policy null and void as respects the perils of Fire and Related Smoke Damage.